

## CONFIRMATION

### BREEAM-International (2016) BREEAM-SE (2017)

### Almedalsgolv kubb Base, Ek, Obehandlad

supplied by  
**Almedals Trägolvsaktiebolag**

RISE Research Institutes of Sweden AB received from Almedals Trägolvsaktiebolag a product sample which is representative of the manufactured product. It has been tested in accordance with relevant test method (ISO 16000-9), see test report 8P02728-12, dated 2018-09-27.

The test results prove that the product qualifies for BREEAM International (2016, issue 2.0) and BREEAM-SE (2017, v 1.0) requirements in Hea 02, **Emission criteria**, for Wood-based products including wood flooring, by complying with:

	<b>Formaldehyde</b> (mg/m <sup>3</sup> )	<b>TVOC</b> (mg/m <sup>3</sup> )	<b>Carc. cat 1A&amp;1B</b> (mg/m <sup>3</sup> )
<b>Table 17: Emission criteria</b>	<b>≤ 0.060</b>	<b>≤ 1.0</b>	<b>≤ 0.001</b>
<b>Test results</b>	<b>0.027</b>	<b>0.029</b>	<b>&lt; 0.001</b>

**RISE Research Institutes of Sweden AB**  
Chemistry and Materials - Chemistry

Maria Rådemar

**RISE Research Institutes of Sweden AB**

Postal address  
Box 857  
SE-501 15 BORÅS  
Sweden

Office location  
Brinellgatan 4  
SE-504 62 BORÅS

Phone / Fax / E-mail  
+46 10 516 50 00  
+46 33 13 55 02  
info@ri.se

This document may not be reproduced other than in full, except with the prior written approval of RISE.